



"औद्योगिक, पर्यटकीय र हरित नगर, स्वच्छ, सुरक्षित र समृद्ध नगर"
दमक नगरपालिका
नगर कार्यपालिकाको कार्यालय



प.सं.:
च.नं.: 6066



☎: ०२३-५९७०००

मिति: २०८३।०२।२९

श्री सूचिकृत फर्म/कम्पनीहरू,
सवै।

बिषय: दरभाउपत्र पेश गर्ने बारे।

प्रस्तुत बिषयमा दमक नगरपालिका मातहतमा रहेको दमक अस्पताल प्रयोजनको लागि 1.5 Ton, 1 Ton AC and Accessories खरिद गर्नु पर्ने भएको हुँदा यसै सूचना साथ संलग्न Bill of Quantities (BOQ) बमोजिम हुने गरि दरभाउपत्र संलग्न फर्मेट वा कम्प्युटराईज टाईप गरि ७ दिन भित्र आर्थिक प्रस्ताव पेश गर्नुहुन जानकारी गराइन्छ। सूचिकृत नभएका फर्म/कम्पनीहरूले सूचिकृत हुने प्रक्रिया पूरा गरी प्रस्ताव पेश गर्न सक्नुहुनेछ।

- प्रस्ताव पेश गर्ने अन्तिम मिति: २०८३।०२।२७ गते कार्यालय समय भित्र।
- पेश गर्ने विधि: कार्यालयमा उपस्थित भएर वा इमेल मार्फत damakhospital03@gmail.com वा info@damakmun.gov.np मा।
- दरभाउपत्र साथ संलग्न राख्नुपर्ने कागजातहरू:
 - दमक अस्पतालमा सूचिकृत भएको निस्सा प्रमाण
 - फर्म/कम्पनी दर्ता प्रमाणपत्रको प्रतिलिपि
 - भ्याट/पान दर्ता प्रमाणपत्रको प्रतिलिपि
 - आ.व. २०८१/०८२ को करचुक्ता प्रमाणपत्रको प्रतिलिपि
- थप जानकारीको लागि दमक अस्पतालको जिन्सी शाखामा कार्यालय समयभित्र सम्पर्क गर्न सक्नुहुनेछ।


.....
सुनिल निरोला
प्रमुख प्रशासकीय अधिकृत



दमक नगरपालिका
दमक अस्पताल
दमक, झापा
कोशी प्रदेश, नेपाल

सुनिल निरीला
प्रमुख प्रशासकीय अधिकृत

आ.व. २०८२/०८३

दमक अस्पताल प्रयोजनको लागि AC तथा Accessories को दरभाउपत्र पेश गर्ने प्रयोजनको लागि

SN	Item Name	Unit	Quantity	Rate	Total Cost
1	AC 1.5 Ton Inverter Split Air Conditioner with Outdoor Unit, Wall Mount Bracket, min 3m Inlet and Outlet Copper Pipe Set	Pcs	2		
2	AC 1 Ton Inverter Split Air Conditioner with Outdoor Unit, Wall Mount Bracket, min 3m Inlet and Outlet Copper Pipe Set	Pcs	4		
3	CPVC Pipe SDR 11(28.1kg/cm ²). 0.75" with J hook nails and accessories for waste water drain	m	30		
4	0.75" CPVC 90 degree elbow	pcs	10		
5	0.75" CPVC Plain Socket	pcs	6		
6	1 Meter Copper Inlet and Outlet set rate (including Pipe, insulator, Tape etc)	m	1		
7	Power Socket with PVC Box	pcs	6		
A	Total (Excluding VAT)				
B	13% VAT				
C	Grand Total				



सुबिला निरीला
 2021-082
 प्रमुख प्रसिद्धि अधिकृत

1.5 Ton DC Inverter Split Type Wall mounted Air Conditioner			Firm Compliance	Remarks
Feature	Specification			
Country of Origin	To be specified by Bidder			
Manufacture and Brand	To be specified by Bidder			
Model No of Indoor Unit	To be specified by Bidder			
Model No of Outdoor Unit	To be specified by Bidder			
Compressor Manufacturer Name	To be specified by Bidder			
Compressor Brand Name	To be specified by Bidder			
Model No of Compressor	To be specified by Bidder			
Type	Wall Mount DC Inverter			
Function	Cooling & Heating			
Standard Test Condition	Cooling : Outdoor: DBT 35 degree C / WBT 24 degree C, Indoor: DBT 27 degree C / WBT 19 degree C Heating : Outdoor: DBT 7 degree C / WBT 6 degree C, Indoor: DBT 20 degree C / WBT 15 degree C			
Operating Range	Cooling: ≥ 16 to ≤ 30 degree C, Heating: ≥ 16 to ≤ 30 degree C			
Fan Speed	min 3 Step			
Capacity	Btu/Hr	Greater than 17500		
Cooling Capacity Standard	W	5100 or Better		
Heating Capacity Standard	W	5100 or better		
Power Input Standard Cooling	W	Less or equal to 1780W,		
Maximum Power Input Cooling	W	Less or Equal to 2500		
Power Input Standard Heating	W	Less or Equal to 1850 W		
Maximum Power Input Heating	W	Less or Equal to 2500 W		
EER Cooling	BTU/Hr/W	10 or better		
COP	W/W	3.5 or better		
Moisture Removal	L/h	1.2		
Air Circulation (Indoor/Hi)	m ³ /min	15		
Noise Level Outdoor	[dB-A]	Less than 57		
Noise Level Indoor	[dB-A]	Less than 48		
Refrigerant Pipe Diameter				
Liquid Side	mm (inch)	Company Stanadard		
Gas Side	mm (inch)	Company Standard		
Operation Conditions	Outdoor Temperature	-5-46 °C		

[Handwritten Signature]



सुजित निरोला
प्रमुख प्रशासकीय अधिकृत

Operation Conditions	Outdoor Temperature	-5-46 °C		
	Voltage	220 V (1 Phase)		
	Frequency	50 Hz		
Refrigerant Gas		R410a or R32 or similar		
Condenser Type	Air cooled Condenser with, DC inverter Compressor,			
Features	Eco Function,			
Warranty	2 year Service (AC inspection and Free cleaning service (Air filter, Coils, Fins) in every 6 months for 2 years. and Comprehensive warranty (Covers repairs, rectification or replacement of components including the IDU or ODU, IDU Evaporator Coil, ODU condenser Coil, Gas charging) and min 5 years on compressor			
Certificate	ISO 9001 certified company. IAF Accrediated Certifying Orgaization			
Documentation	Specification must be verifyable from OEM website by brand and model number or must submit the valid catalogue from the manufacture. The catalogue must clearly show the specified Specification.			



सुनिल गिरीला
 अधिकृत
 FY: 2022-23

1 Ton DC Inverter Split Type Wall mounted Air Conditioner			Firm Compliance	Remarks
Feature	Specification			
Country of Origin	To be specified by Bidder			
Manufacture and Brand	To be specified by Bidder			
Model No of Indoor Unit	To be specified by Bidder			
Model No of Outdoor Unit	To be specified by Bidder			
Compressor Manufacturer Name	To be specified by Bidder			
Compressor Brand Name	To be specified by Bidder			
Model No of Compressor	To be specified by Bidder			
Type	Wall Mount DC Inverter			
Function	Cooling & Heating			
Standard Test Condition	Cooling : Outdoor: DBT 35 degree C / WBT 24 degree C, Indoor: DBT 27 degree C / WBT 19 degree C Heating : Outdoor: DBT 7 degree C / WBT 6 degree C, Indoor: DBT 20 degree C / WBT 15 degree C			
Operating Range	Cooling: ≥ 16 to ≤ 30 degree C, Heating: ≥ 16 to ≤ 30 degree C			
Fan Speed	min 3 Step			
Capacity	Btu/Hr	Greater than 11900		
Cooling Capacity Standard	W	3500 or Better		
Heating Capacity Standard	W	3500 or better		
Power Input Standard Cooling	W	Less or equal to 1150W,		
Maximum Power Input Cooling	W	Less or Equal to 1650 W		
Power Input Standard Heating	W	Less or Equal to 1150 W		
Maximum Power Input Heating	W	Less or Equal to 1500 W		
EER Cooling	BTU/Hr/W	10 or better		
COP	W/W	3.5 or better		
Moisture Removal	L/h	1		
Air Circulation (Indoor/Hi)	m3/min	10		
Noise Level Outdoor	[dB-A]	Less than 57		
Noise Level Indoor	[dB-A]	Less than 45		
Refrigerant Pipe Diameter				
Liquid Side	mm (inch)	Company Stanadard		
Gas Side	mm (inch)	Company Standard		



सुनिल निरौला
प्रमुख प्रशासकीय अधिकृत

	Voltage	220 V		
	Frequency	50 Hz		
	Refrigerant Gas	R410a or R32 or similar		
	Condenser Type	Air cooled Condenser with, DC inverter Compressor, Multispeed condenser fan and golden finned copper condenser.		
	Features	Eco Function, Horizontal and Vertical Auto Swing Louver, Indoor Unit Evaporator should be made of Aluminum Fin or better with a copper tube.		
	Warranty	2 year Service (AC inspection and Free cleaning service (Air filter, Coils, Fins) in every 6 months for 2 years. and Comprehensive warranty (Covers repairs, rectification or replacement of components including the IDU or ODU, IDU Evaporator Coil, ODU condenser Coil, Gas charging) and min 5 years on compressor		
	Certification	ISO 9001 certified company. IAF Accrediated Certifying Orgaization		
	Documentation	Specification must be verifyable from OEM website by brand and model number or must submit the valid catalogue from the manufacture. The catalogue must clearly show the specified Specification.		